

Annexure C


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No 3950

Dated 08/6/2026

It is certified that an inspection team headed by Sh. Raj Kumar Junior Engineer. (Name of Officers with designation) from Sh. Raj Kumar Junior Engineer PHED inspected the Akal Academy Tibber Distt Gurdaspur (Name & Address of the school) on (date of inspection) and on the basis of Water Test Report (Attached) bearing no. DWTLGSP/2627/00042 dated.30.04.2026 of .(PHED Lab) certified that the Akal Academy Tibber Distt Gurdaspur (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central State/UT. Govt.

This certificate is valid till...01-04-2026 to 31-03-2027.


Executive Engineer,
Water Supply & Sanitation Division No.1,
Gurdaspur


To


Akal Academy Tibber,

District Gurdaspur

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer/PHED Lab / local bodies


Manager
Akal Academy
Tibber (Gsp.)


Principal
Akal Academy Tibber (Gsp.)
CBSE Aff. No. 1631030

REGIONAL WATER TESTING LAB, AMRITSAR

New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com

To,

Principal Akal Academy
V.P.O. Tibber, Distt Gurdaspur


No.: RWTLASR/2627/00158 Dated : 06/05/2026

Subject : Testing Reports of Water Samples.


Reference: Your Letter/SRF No. 459 Dated: 29/04/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample received on dated 04/05/2026. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Amritsar


D/A : Test Report



Authorized Signatory
For, Regional Water Testing Lab
Amritsar



Manager
Akal Academy
Tibber (Gsp.)




Principal
Akal Academy Tibber (Gsp.)
CBSE Aff. No. 1631030

REGIONAL WATER TESTING LAB, AMRITSAR
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com


TEST REPORT						
Name & Address of Customer : Principal Akal Academy V.P.O. Tibber, Distt Gurdaspur			Customer Reference No.		No : 459 Dated : 29/04/2026	
			Sample Submitted by		Mr.Gagandeep Singh	
			Date of Sample Receipt		04/05/2026	
			Analysis Starting Date		04/05/2026	
			Analysis completion Date		04/05/2026	
Discipline : Chemical Testing			Group: Water			
ULR No.:				Sample Type :		Water
Test Report No.:		RWTLASR/2627/00158		Date of Issue :		06/05/2026
Registration no.:		RWTLASR/REG2627/00542		Condition of Sample :		Sealed
Collection Point:		Private Submersible		Quantity/Type of Bottle:		1000 ml / Amber Colored Glass Bottle
Scheme/Source:		Not Mentioned(Not Mentioned)		Location/Depth :		Tibber(S/pump 350 ft),Sample Collected By Rajkumar JE(7009511649) / 350 ft
Village :		Not Mentioned		Habitation :		Not Mentioned
Block:		Not Mentioned		District :		Gurdaspur
Latitude :		Not Mentioned		Longitude:		Not Mentioned
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	Aluminium(Al)	0.045	0.03	0.2	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
2	Lead	0.007	0.01	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
3	Selenium	0.005	0.01	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
4	Chromium(Cr)	BDL(0.005)	0.05	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
5	Mercury	BDL(0.0005)	0.001	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
6	Arsenic(As)	BDL(0.005)	0.01	No relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
7	Cadmium(Cd)	0.0007	0.003	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
8	Nickel	BDL(0.005)	0.02	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
9	Iron(Fe)	0.063	1	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
10	Copper(Cu)	0.012	0.05	1.5	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
11	Uranium	6.665	30	No Relaxation	µg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
12	Manganese(Mn)	BDL(0.005)	0.1	0.3	mg/l	APHA (24th Ed. 2023) Method :3125 B By ICPMS
13	Zinc(Zn)	0.303	5	15	mg/l	APHA (24th Ed. 2023) Method: 3125 B By ICPMS


Continue on next page...

Reviewed and Approved By



Mr. Pardeep kumar
Quality Manager
Authorized Signatory
For,Regional Water Testing Lab
Amritsar


Manager
Akal Academy
Tibber (Gsp.)


Principal
Akal Academy Tibber (Gsp.)
CBSE Aff. No. 1631030


REGIONAL WATER TESTING LAB, AMRITSAR
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com

14	Barium	0.141	0.7	No Relaxation	mg/l	APHA (24th Ed.2023) Method: 3125 B By ICPMS
----	--------	-------	-----	---------------	------	---

This Report is issued under the following terms & Condition :


1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By




Mr. Pardeep kumar
Quality Manager
Authorized Signatory
For,Regional Water Testing Lab
Amritsar

----- End of the Test Report -----



Manager
Akal Academy
Tibber (Gsp.)



Principal
Akal Academy Tibber (Gsp.)
CBSE Aff. No. 1631030